

View of protective scaffolding at Tower C entry



View of protective scaffolding at Schwartz Hall entries




View of protective scaffolding at walkways leading to Tower A and Tower B entries



View of the roofs at Tower C and Tower D

Slide #24



View of the cracks and voids in the underside of the concrete slab at Tower C entry.



View of moisture staining in plaster ceiling in Tower A



View of moisture staining on wood structure and corroded metal in Tower B



View of moisture staining of wood structure in Tower C



View of moisture staining on damaged plaster ceiling in Tower E



View of moisture damage on plaster and corroded metal structure in Tower A abandoned stairway



View of plaster damage and corrosion at Tower A abandoned stairway

Slide #31



View of plaster damage and corrosion at Tower A abandoned stairway



View of the cracked concrete and exposed reinforcing at Tower A abandoned stair